



January 18, 2023

Dear Valued Customer,

This letter serves the document that states that Vinyl Efx Decorative passes ASTM E-84-11a (Standard Test Method for Surface Burning Characteristics of Building Materials) and falls under classification “A” concluded by laboratory evaluations completed by Architectural Laboratory on June 20, 2012. No changes to the product have been made since this testing was conducted.

Actual Data Summary of ASTM E84-11a

Classification	Flame Spread Index	Smoke Developed Index
A	20	25

ASTM Classified Category

Classification	Flame Spread Index	Smoke Developed Index
A	0-25	0-450
B	26-75	0-450
C	76-200	0-450

If you have any questions or require additional information, please feel to contact us at orders@rtape.com.

Sincerely,

Mitchell Blumenthal

Mitchell Blumenthal
R&D Manager-Adhesives
Nekoosa Corporation